



Boise City Fire Department Permit Supplemental Information

#31 – Open Flames and Candles

The following list is given to you as a courtesy to help expedite the permit process. Completing these items does not guarantee approval. Full review of the plans you provide followed by a site inspection are still required for approval by the Fire Department.

Per NFPA 160 and Section 307.4.1 International Fire Code

- Fire Department will need a site plan including:
 - A Narrative Description of the flame effect
 - The Location of flame effect devices to be fired and their controls and control sequence
 - Area affected by the flame effect device
 - Location of the Audience
 - Fuels to be used and means of igniting
 - Storage areas of flammable and combustible materials
 - Fire protection features
 - Emergency plan including egress

- All Flame Effect operators shall:
 - be 21 years of age
 - NOT be under the influence of Alcohol, Narcotics, or any other medication, illicit or prescribed, that can impair judgment.

- Other things to be prepared for:
 - Any other information required by the Fire Department not already included
 - Portable Fire Extinguisher(s)
 - “NO SMOKING” Signs
 - If available – Video copy of previous similar performance - website link acceptable also