



## IRC Code Handout Emergency Escape & Rescue Openings

### Section R310: Emergency Escape & Rescue Openings:

Basements, habitable attics and every sleeping room shall have not less than one operable emergency escape and rescue opening. Where basements contain one or more sleeping rooms, an emergency escape and rescue opening shall be required in each sleeping room. Emergency escape and rescue openings shall open directly into a public way, or to a yard or court that opens to a public way.

#### Exceptions:

1. Storm shelters and basements used only to house mechanical equipment not exceeding a total floor area of 200 square feet (158.58 m<sup>2</sup>).
2. Where the dwelling or townhouse is equipped with an automatic sprinkler system installed in accordance with Section P2904, sleeping rooms in basements shall not be required to have emergency escape and rescue opening provided that the basement has one of the following:
  - 2.1 One means of egress complying with Section R311 and one emergency escape and rescue opening.
  - 2.2 Two means of egress complying with Section R311.

#### Operational constraints and opening control devices:

Emergency escape and rescue openings shall be operational from the inside of the room without the uses of keys, tools or special knowledge. Window opening control devices on windows serving as a required emergency escape and rescue opening shall comply with ASTM F2090.

#### Emergency escape and rescue openings:

Emergency escape and rescue openings shall have minimum dimensions as specified in this section.

**Minimum opening area:** Emergency escape and rescue openings shall have a net clear opening of not less than 5.7 square feet (0.0530 m<sup>2</sup>). The net clear opening dimensions required by this section shall be obtained by the normal operation of the emergency escape and rescue

opening from the inside. The net clear height of the opening shall be not less than 24 inches (610 mm) and the net clear width shall be not less than 20 inches (508 mm).

**Exception:** Grade floor openings or below-grade openings shall have a net clear opening area of not less than 5 square feet (0.465 m<sup>2</sup>).

**Window Sill Height:** Where a window is provided as the emergency escape and rescue opening, it shall have a sill height of not more than 44 inches (1118mm) above the floor; where the sill height is below grade, it shall be provided with a window well in accordance with Section R310.2.3.

**Replacement windows:** Replacement windows installed in buildings meeting the scope of this code shall be exempt from the maximum sill height requirements of Section R310.2.2 and the requirements of Section R310.2.1, provided that the replacement window meets the following conditions:

1. The replacement window is the manufacturer's largest standard size window that will fit within the existing frame or existing rough opening. The replacement window is of the same operating style as the existing window or a style that provides for an equal or greater window opening area than the existing window.
2. The replacement window is not part of a change of occupancy.

**Window wells:** The horizontal area of the window shall be not less than 9 square feet (0.90 m<sup>2</sup>), with a horizontal projection and width of not less than 36 inches (914 mm). The area of the window well shall allow the emergency escape and rescue opening to be fully opened.

**Exception:** The ladder or steps required by Section R310.2.3.1 shall be permitted to encroach not more than 6 inches (152 mm) into the required dimensions of the window well.

**Ladder and steps:** Window wells with a vertical depth greater than 44 inches (1118 mm) shall be equipped with a permanently affixed ladder or steps usable with the window in the fully open position. Ladders or steps required by this section


shall not be required to comply with Section R311.7. Ladders or rungs shall have an inside width of not less than 12 inches (305 mm), shall project not less than 3 inches (76 mm) from the wall and shall be spaced not more than 18 inches (457 mm) on center vertically for the full height of the window well.

**Drainage:** Window wells shall be designed for proper drainage by connection to the building's foundation drainage system required by Section R405.1 or by an approved alternative method.

**Exception:** A drainage system for window wells is not required where the foundation is on well-drained soil or sand-gravel mixture soils in accordance with the Unified Soil Classification System, Group I Soils, as detailed in Table R405.1.0

**Emergency escape and rescue openings under decks and porches:** Emergency escape and rescue openings installed under decks and porches shall be fully openable and provide a path not less than 36 inches (914 mm) in height to a yard or court.

## Window Well



## Emergency Escape and Rescue Window

