

## City Code - Title 5 Chapter 12: FIRE PREVENTION CODE

Revise Section 5-12-35 to read as follows:

### 5-12-35: IFC AMENDMENT, ADD SECTION 903.3.5.3, CONTROL VALVE LOCATION:

**903.3.5.3 Control Valve Location.** Fire sprinkler system main control valves shall be located in a fire sprinkler riser room that is separated from the building on all sides by a one-hour fire ~~rated assembly~~ barrier, horizontal assembly, or both, including opening and penetration protection, as defined by the Building Code. The fire sprinkler riser room shall be provided with an exterior door that opens directly into the room.

**Exception:** Sprinkler systems provided with post indicator valves located in an approved location.

Revise Section 5-12-37 to read as follows:

### 5-12-37: IFC AMENDMENT, SECTION 903.4.3, FLOOR CONTROL ~~VALVES~~ ASSEMBLY:

**903.4.3 Floor Control ~~Valves~~ Assembly.** Unless otherwise approved by the fire code official, supervised ~~indicating floor~~ control ~~valves~~ assemblies shall be provided at the point of connection on each floor in buildings ~~two (2)~~ four (4) or more stories in height.

#### Exceptions:

1. One- and two-family dwellings.
- ~~2. Buildings less than or equal to three (3) stories in height with floor areas less than 5,000 square feet.~~

Revise Section 5-12-60 to read as follows:

### 5-12-60: IFC AMENDMENT, ADOPT APPENDIX L, ~~HAZARD-RANKING~~ REQUIREMENTS FOR FIRE FIGHTER AIR REPLENISHMENT SYSTEMS:

Adopt Appendix L, ~~Hazard-Ranking~~ Requirements for Fire Fighter Air Replenishment Systems.

Revise Section 5-12-61 to read as follows:

**5-12-61: IFC AMENDMENT, APPENDIX L, L101.1, SCOPE:**

**L101.1 Scope.** Amend ~~the first sentence~~ section to read as follows:

~~When provided, firefighter air replenishment systems (FARS) shall comply with the provisions of this appendix.~~ Fire fighter air replenishment systems (FARS) shall be provided in accordance with this appendix and installed in all new buildings with an occupied floor more than 120 feet above the lowest level of fire department vehicle access.